



# CE-CERTIFICATE

## **CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw1444\_2023**

According to reports N° 22.06687.01, 22.06690.01 and 23.01123.1 dated on 30/01/23, 02/02/23 and 13/04/23, we confirm that the below mentioned items were tested at CENTEXBEL, Notified body #0493, with reference to EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics.

The item shows

EU fire classification: B<sub>fl</sub>-s1  
Loose laid on a non-combustible substrate<sup>1</sup>  
Compliance with content of pentachlorophenol  
Formaldehyde class: E1  
Dynamic coefficient of friction: Dry slip resistance  
Antistatic floor covering  
Thermal resistance: 0.0075 m<sup>2</sup>. K/W

<sup>1</sup>End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics . These products come under the EU CPR 305/2011 directives for product safety.

Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

**Product family  
Company**

**SPC Flooring: 8.2 - 11.4 kg/m<sup>2</sup> and 4 - 5.5 mm  
Anhui Yangzi Meijia New Material Technology Co., Ltd.  
No.318, West Yuan Road Laian County,  
Chuzhou City 239200 ANHUI  
CHINA**

Certificate No. jw1444\_2023 is valid until 29/01/2028  
Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 21/04/2023

Inge De Witte, PhD  
Certification Manager