



CE-CERTIFICATE

CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw2318_2023

According to reports N° 23.02321.01, 23.02321.02, 23.02335.01, 23.02335.02 and 23.02335.03 dated on 30/06/23 and 13/04/23, we confirm that the below mentioned items were tested at CENTEXBEL, Notified body ≠0493, with reference to EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics.

The item shows

EU fire classification: B_{fl}-s1
Glued on a non-combustible substrate¹
Formaldehyde class: E1
Thermal resistance: 0.0166 m². K/W

¹End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 14041:2004+AC:2006 – Resilient, textile and laminate floor coverings - Essential characteristics . These products come under the EU CPR 305/2011 directives for product safety.

Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Product family	Vinyl flooring 2-5 mm
Company	Anhui Yangzi Meijia New Material Technology Co., Ltd. No.318, West Yuan Road Laian County, Chuzhou City 239200 ANHUI CHINA

Certificate No. jw2318_2023 is valid until 29/06/2028
Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 5/07/2023

Inge De Witte, PhD
Certification Manager